

DEPARTMENT OF FISCAL SERVICES

PURCHASING DIVISION



February 23, 2005

To: PROSPECTIVE PROPOSERS AND ALL OTHERS CONCERNED

From: Tammy L. Roberts, CPPB, Sr. Contracts Analyst

Subject: BD-2115-05/TLR – Facilities Maintenance Emergency Generator

Due Date: March 02, 2005 @ 2:00 PM

ADDENDUM #1

Total pages: 1

The information included in this Addendum revises, clarifies, or supplements the specifications and other provisions of the contract documents and is considered part and parcel to the RFP/BID Package.

The prospective contractor will not be required to move the generator to the new pad. Seminole County Facilities Maintenance will move the generator and set it in place.

QUESTION from Hicks Electric: Please advise the interrupting capacity of the MDP, 300AMP, 2-POLE MCB, Panel EM1, EMA, EMB.

RESPONSE: On Sheet E401, the AIC rating for Existing panel, Panel 'MDP' is existing and if any breakers are installed in the panel, contractor shall match AIC rating of the highest AIC rated breaker in panel. For 300 Amp enclosed breaker, AIC rating shall be 65 KAIC. For Panels 'EM1', 'EMA' and 'EMB' AIC rating shall be 42 KAIC.

Failure to acknowledge receipt of this addendum on the submittal may result in disqualification of your bid response.

Signature on File

Peter W. Maley, C.P.M., CPCM
Contracts Supervisor